
Newfoundland Labrador Hydro (NLH) Supply and Demand Status Report Filed Monday, March 25, 2024

Section 1

Island Interconnected System - Supply, Demand & Exports Actual 24 Hour System Performance For Sunday, March 24, 2024



Island Supply Notes For March 24, 2024

- A As of 0800 hours, May 21, 2023, Holyrood Unit 2 unavailable due to forced extension to planned outage (170 MW).
- As of 2059 hours, July 13, 2023, Stephenville Gas Turbine unavailable due to forced outage (50 MW).
 - As of 1400 hours, February 06, 2024, St. Anthony Diesel Plant available at 8.7 MW due to forced derating (9.7 MW).
- As of 1102 hours, March 06, 2024, Holyrood Unit 1 available at 160 MW (170 MW).
- As of 1808 hours, March 15, 2024, Labrador Island Link available at 450 MW due to forced derating (700 MW) Bipole.
- At 0851 hours, March 24, 2024, Hinds Lake Unit unavailable due to planned outage (75 MW).

Section 2

Island Interconnected System - Supply, Demand & Outlook

Mon, Mar 25, 2024	Island System Outlook ²	Seven-Day Forecast	Island System Daily Peak Demand (MW)	
			Forecast ⁸	$\mathbf{Adjusted}^6$
Island System Supply: ⁴	1,738 MW	Monday, March 25, 2024	1,335	1,240
NLH Island Generation: ^{3,7}	1,385 MW	Tuesday, March 26, 2024	1,350	1,254
NLH Island Power Purchases:5	115 MW	Wednesday, March 27, 2024	1,325	1,230
NP and CBPP Owned Generation:	225 MW	Thursday, March 28, 2024	1,215	1,121
LIL Net Imports to Island: 9	13 MW	Friday, March 29, 2024	960	869
		Saturday, March 30, 2024	1,000	908
7-Day Island Peak Demand Forecast:	1,350 MW	Sunday, March 31, 2024	1,010	918

Island Supply Notes For March 25, 2024

At 0701 hours, March 25, 2024, Labrador Island Link available at 450 MW due to planned derating (700 MW) - Monopole.

otes: 1. Generation outages for running and corrective maintenance are included. These are not unusual for power system operations. They generally do not impact customer supply. Hydro schedules outages to system equipment whenever possible to coincide with periods when customer demands are low and sufficient supply reserves are available. However, from time to time equipment outages are necessary and reserves may be impacted.

- 2. As of 0800 Hours.
- ${\bf 3.}\ Gross\ continuous\ unit\ output.$
- 4. Gross output from all Island sources (including Note 4).
- 5. NLH Island Power Purchases include: ML Imports, Exploits Generation, Rattle Brook, Star Lake, Wind Generation and capacity assistance (when applicable).
- 6. Adjusted for interruptible load and the impact of voltage reduction when applicable.
- 7. Due to limitations inherent in the design of combustion turbines, the output of combustion turbines may be reduced in the event that ambient temperatures exceed the threshold required for full rated output. This threshold is dependent on the design of each turbine.
- 8. Does not include ML Exports.
- 9. LIL Import sunk in the Island System. Actual LIL flows will be restricted by various system conditions including, but not limited to, Island Load, ML Exports and Avalon Unit status.

Section 3 Island Peak Demand and Exports Information Previous Day Actual Peak and Current Day Forecast Peak				
Island Peak Demand ¹⁰	9:10	1,246 MW		
Exports at Peak		343 MW		
LIL Net Imports to Island		1,452 MWh		
Forecast Island Peak Demand		1,335 MW		
	Previous Day Actual Peak and Current Design Island Peak Demand 10 Exports at Peak LIL Net Imports to Island	Previous Day Actual Peak and Current Day Forecast Peak Island Peak Demand ¹⁰ Exports at Peak LIL Net Imports to Island		

Notes: 10. Island Demand is supplied by NLH generation and purchases, LIL Imports plus generation owned and operated by Newfoundland Power and Corner Brook Pulp & Paper (Deer Lake Power, DLP).